CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3725-0006:108 Page 1 of 1

CATEGORY: Door Hardware (Fire Rated)

LISTEE: Sargent Mfg., 100 Sargent Drive, New Haven CT 06536

Contact: *Dan Picard (203) 498-5634 Fax (203) 498-5600

DESIGN: Rim Type, Models 12-58-8800 and 12-55-58-8800; Vertical Rod, Models 12-58-8700 and 12-55-

> 58-8700; Mortise lock, Models 12-58-8300, 12-58-8900, 12-55-58-8300 and 12-55-58-8900; Concealed Vertical Rod Type, Models 12-58-8400, 12-55-8600, 12-55-58-8400 and 12-55-58-8600 fire exit hardware. Models 12-55-8400, -8600 and 12-55-58-8400, -8600 may have prefix -WD (wood door) or -MD (metal door). Units are provided with a horizontal crossbar which when depressed will retract the latch or latches and open the door. The prefix 55- indicates a signal switch and -58 indicates electric dogging. Refer to listee's data sheet for additional

detailed product description and operational considerations.

RATING: **24 VDC**

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and

in a manner acceptable to the authority having jurisdiction. These devices are intended for

installation on single or double outward swinging doors.

MARKING: Listee's name, model number, rating and UL label.

APPROVAL: Listed as fire rated door hardware for use on single or double outward swinging fire doors.

*Rev. 06-08-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsementor recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

JUNE 6, 2003 Date Issued: Listing Expires June 30, 2004

Authorized By: DIANE K. AREND, Senior Deputy

Program Manager